




# Monarch Laboratory, Inc.

Owned & operated by  FGL Environmental

Page 1 of 1  
TEST REPORT: 245161

DURHAM PUMP, INC.  
P.O. BOX 60  
DURHAM, CA 95938-0000



Sample Identification: **GMWC WELL**  
Date & Time Taken: **03/21/2007 1330**  
Collected By: **KEVIN O'SHEA**  
Sample Matrix: **Liquid**  
Received: **03/21/2007** Client: **DUR110** Report Date: **03/23/2007**  
Other Data: **SPECIAL**  
TEMPERATURE: 13 DEGREES C

### Results for Sample 245161

Parameter	Result	Unit	MAL
001 Total Coliform	ABSENCE	#/100 mL	

### Analytical Details for Sample 245161

Parameter	CAS	Method	Bottle	Analyzed	By
001 Total Coliform		Colisure, SM 9223B		03/23/2007	IKX

### Bottle Data for Sample 245161

**Bottle** #01 - 125 ML, PLASTIC, NA2S2O3  
Derived in Lab From

### Bottle Tracking for Sample 245161

Bottle #: 01 125 ML, PLASTIC, NA2S2O3  
03/21/2007 16:01 DC  
03/21/2007 16:01 DC

0771478  
EMAIL: KOSHEA@DPUMP.COM

Coliform bacteria/E. coli are absent. Water is suitable for domestic consumption.

**Corporate Offices & Laboratory**  
P.O. Box 272/853 Corporation Street  
Santa Paula, CA 93061  
TEL: 805.392.2000  
FAX: 805.525.4172  
CA NELAP Certification No. 01110CA  
CA ELAP Certification No.1573

**Office & Laboratory**  
2500 Stagecoach Road  
Stockton, CA 95215  
TEL: 209.942.0181  
FAX: 209.942.0423  
CA ELAP Certification No. 1563

**Office & Laboratory**  
563 E. Lindo Avenue  
Chico, CA 95926  
TEL: 530.343.5818  
FAX: 530.343.3807  
CA ELAP Certification No. 1562

**Field Office**  
Visalia, California  
TEL: 559.734.9473  
FAX: 559.734.8435  
Mobile: 559.737.2399



# Monarch Laboratory, Inc.

Owned & operated by  FGL Environmental

Page 1 of 1  
TEST REPORT: 245162

DURHAM PUMP, INC.  
P.O. BOX 60  
DURHAM, CA 95938-0000

RECEIVED  
MAR 27 2007  
BY: \_\_\_\_\_

Sample Identification: **GMWC ROCKY BLUFFS**  
Date & Time Taken: **03/21/2007 1500**  
Collected By: **KEVIN O'SHEA**  
Sample Matrix: **Liquid**  
Received: **03/21/2007** Client: **DUR110** Report Date: **03/23/2007**  
Other Data: **SPECIAL**  
TEMPERATURE: 13 DEGREES C

### Results for Sample 245162

Parameter	Result	Unit	MAL
001 Total Coliform	ABSENCE	#/100 mL	

### Analytical Details for Sample 245162

Parameter	CAS	Method	Bottle	Analyzed	By
001 Total Coliform		Colisure, SM 9223B		03/23/2007	IKX

### Bottle Data for Sample 245162

**Bottle** #01 - 125 ML, PLASTIC, NA2S2O3  
**Derived in Lab From**

0771478  
EMAIL: KOSHEA@DPUMP.COM

Coliform bacteria/E. coli are absent. Water is suitable for domestic consumption.

**Corporate Offices & Laboratory**  
P.O. Box 272/853 Corporation Street  
Santa Paula, CA 93061  
TEL: 805.392.2000  
FAX: 805.525.4172  
CA NELAP Certification No. 01110CA  
CA ELAP Certification No.1573

**Office & Laboratory**  
2500 Stagecoach Road  
Stockton, CA 95215  
TEL: 209.942.0181  
FAX: 209.942.0423  
CA ELAP Certification No. 1563

**Office & Laboratory**  
563 E. Lindo Avenue  
Chico, CA 95926  
TEL: 530.343.5818  
FAX: 530.343.3807  
CA ELAP Certification No. 1562

**Field Office**  
Visalia, California  
TEL: 559.734.9473  
FAX: 559.734.8435  
Mobile: 559.737.2999



# Monarch Laboratory, Inc.

Owned & operated by  FGL Environmental

Page 1 of 1  
TEST REPORT: 245163

DURHAM PUMP, INC.  
P.O. BOX 60  
DURHAM, CA 95938-0000



Sample Identification: **GMWC SKANSEN**  
Date & Time Taken: **03/21/2007 1508**  
Collected By: **KEVIN O'SHEA**  
Sample Matrix: **Liquid**  
Received: **03/21/2007** Client: **DUR110** Report Date: **03/23/2007**  
Other Data: **SPECIAL**  
TEMPERATURE: 13 DEGREES C

### Results for Sample 245163

Parameter	Result	Unit	MAL
001 Total Coliform	ABSENCE	#/100 mL	

### Analytical Details for Sample 245163

Parameter	CAS	Method	Bottle	Analyzed	By
001 Total Coliform		Colisure, SM 9223B		03/23/2007	IKX

### Bottle Data for Sample 245163

**Bottle** #01 - 125 ML, PLASTIC, NA2S2O3  
**Derived in Lab From**

0771478  
EMAIL: KOSHEA@DPUMP.COM

Coliform bacteria/E. coli are absent. Water is suitable for domestic consumption.

**Corporate Offices & Laboratory**  
P.O. Box 272/853 Corporation Street  
Santa Paula, CA 93061  
TEL: 805.392.2000  
FAX: 805.525.4172  
CA NELAP Certification No. 01110CA  
CA ELAP Certification No.1573

**Office & Laboratory**  
2500 Stagecoach Road  
Stockton, CA 95215  
TEL: 209.942.0181  
FAX: 209.942.0423  
CA ELAP Certification No. 1563

**Office & Laboratory**  
563 E. Lindo Avenue  
Chico, CA 95926  
TEL: 530.343.5618  
FAX: 530.343.3807  
CA ELAP Certification No. 1562


**Field Office**  
Visalia, California  
TEL: 559.734.9473  
FAX: 559.734.8435  
Mobile: 559.737.2399



# Monarch Laboratory, Inc.

Owned & operated by  FGL Environmental

DURHAM PUMP, INC.  
P.O. BOX 60  
DURHAM, CA 95938-0000



Page 1 of 1  
TEST REPORT: 245164

Sample Identification: **GMWC SPANISH GARDEN**  
Date & Time Taken: **03/21/2007 1516**  
Collected By: **KEVIN O'SHEA**  
Sample Matrix: **Liquid**  
Received: **03/21/2007** Client: **DUR110** Report Date: **03/23/2007**  
Other Data: **SPECIAL**  
TEMPERATURE: 13 DEGREES C

### Results for Sample 245164

Parameter	Result	Unit	MAL
001 Total Coliform	ABSENCE	#/100 mL	

### Analytical Details for Sample 245164

Parameter	CAS	Method	Bottle	Analyzed	By
001 Total Coliform		Colisure, SM 9223B		03/23/2007	IKX

### Bottle Data for Sample 245164

**Bottle** #01 - 125 ML, PLASTIC, NA2S2O3  
**Derived in Lab From**

0771478  
EMAIL: KOSHEA@DPUMP.COM

Coliform bacteria/E. coli are absent. Water is suitable for domestic consumption.

**Corporate Offices & Laboratory**  
P.O. Box 272/853 Corporation Street  
Santa Paula, CA 93061  
TEL: 805.392.2000  
FAX: 805.525.4172  
CA NELAP Certification No. 01110CA  
CA ELAP Certification No.1573

**Office & Laboratory**  
2500 Stagecoach Road  
Stockton, CA 95215  
TEL: 209.942.0181  
FAX: 209.942.0423  
CA ELAP Certification No. 1563

**Office & Laboratory**  
563 E. Lindo Avenue  
Chico, CA 95926  
TEL: 530.343.5818  
FAX: 530.343.3807  
CA ELAP Certification No. 1562

**Field Office**  
Visalia, California  
TEL: 559.734.9473  
FAX: 559.734.8435  
Mobile: 559.737.2399