

2010 Consumer Confidence Report

Water System Name: **GRAN MUTUAL WATER CO**

Report Date: **June 2011**

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2010

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water sources(s) in use: According to DHS records, Well #1 is Groundwater. This Assessment was done using the Default Groundwater System Method. This info is not available for Well 02, as it does not have a completed assessment on file. Please see the Drinking Water Source Assessment Information section located at the end of this report for more details.

Your water comes from 2 sources: Well #1 and Well #2.

For more information about this report, or for any questions relating to your drinking water, please call (530) 531 - 5948 and ask for Kevin OShea.

TERMS USED IN THIS REPORT:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Variances and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picograms per liter (pg/L)

pCi/l: picocuries per liter (a measure of radioactivity)

The sources of drinking water(both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, spring, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

2010 Consumer Confidence Report

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Radioactive contaminants*, which can be naturally occurring or the result of oil production and mining activities.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

In order to ensure that tap water is safe to drink, the USEPA and the California Department of Health Services (Department) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Tables 1,2,3,4,5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituents. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, through representative of the water quality, are more than one year old.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	2/mo. (2010)	1	no more than 1 positive monthly sample	0	Naturally present in the environment.

Any violation of MCL, AL or MRDL is shaded. Additional information regarding the violation is provided later in this report.

TABLE 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in the last sample set)	No. of Samples Collected	90th Percentile Level	No. Site Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (ppm)	5 (2010)	0.061	0	1.3	.17	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

2010 Consumer Confidence Report

TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Typical Sources of Contaminant
Sodium (ppm)	2010	7	7 - 7	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2010	115	115 - 115	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Barium (Ba) ppm	2009	0.02	0.02 - 0.03	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits
Chromium (Total Cr) ppb	2009	I	ND - 2	50.0	n/a	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Nitrate (NO3) ppm	2010	1.4	0.8 - 2	45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N ppm	2010	0.4	0.4 - 0.4	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha pCi/L	2009	0.5	0.4 - 0.6	15	n/a	Erosion of natural deposits.
Total Radium 228 pCi/L	2008	0.01	ND - 0.03	5	n/a	Erosion of natural deposits

TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Typical Sources of Contaminant
Chloride ppm	2010	2	2 - 2	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance umhos/cm	2010	238	238 - 238	1600	n/a	Substances that form ions when in water; seawater influence
TDS ppm	2010	140	140 - 140	1000	n/a	Runoff/leaching from natural deposits

2010 Consumer Confidence Report

TABLE 6 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
Vanadium ppm	2009	0.007	0.006 - 0.008 (2009)	50	The babies of some pregnant women who drink water containing vanadium in excess of the action level may have an increased risk of developmental effects, based on studies in laboratory animals.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care provider. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791)

For Lead (Pb), If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. *GRAN MUTUAL WATER CO* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Summary Information for Contaminants Exceeding an MCL, MRDL, or AL, or a violation of Any Treatment Technique or Monitoring and Reporting Requirement

About our Total Coliform Bacteria: Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

2010 Consumer Confidence Report

Drinking Water Source Assessment Information

Assessment Info

A source water assessment was conducted for the ONLY WELL of the GRAN MUTUAL WATER CO water system in June, 2000. According to the Drinking Water Source Assessment and Protection Program's Source Water Assessments Public Access web page, the Public Water Sources WELL 02 of the GRAN MUTUAL WATER CO water system number 0400008, does not have a completed Source Water Assessment on file.

Well 01 - is considered most vulnerable to the following activities not associated with any detected contaminants:
Sewer collection systems

Well 02 - This info is not available.

Discussion of Vulnerability

The drinking water source is considered vulnerable to the listed possible contaminating activities (provided in Vulnerable Ranking section of this report). The listed activities include those associated with sewer collection system that serves the development. Other activities include the storage of construction related equipment and products close to the well.

Assessment summaries are not available for some sources. This is because:

- The Assessment has not been completed. Contact the local Department of Health Services (DHS) Drinking Water field office or the water system to find out when the Assessment is scheduled to be done.
- The source is not active. It may be out of service, or new and not yet in service.
- The Assessment was not submitted electronically. The site used to obtain Assessments only provides access to Assessment summaries submitted electronically.

Acquiring Info

A copy of the complete assessment may be viewed at:
Butte County Environmental Health
202 Mira Loma Dr.
Oroville, CA 95965

You may request a summary of the assessment be sent to you by contacting:
Butte County Environmental Health
Program Manager
530-538-7282
530-538-2165 (fax)

For more info you may visit <http://swap.ice.ucdavis.edu/TSinfo/TSintro.asp> or contact the health department in the county to which the water system belongs.

GRAN MUTUAL WATER CO

Analytical Results By FGL - 2010

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%				33.3 %	1 - 2
WELL#2	CH 1078249-001					12/07/2010	Absent		
SPNSH GRDNS	CH 1078249-002					12/07/2010	Absent		
WELL#2	CH 1077686-001					11/09/2010	Absent		
RKY BLFS	CH 1077686-002					11/09/2010	Absent		
WELL#1	CH 1077235-001					10/18/2010	Present		
WELL#2	CH 1077206-001					10/14/2010	Absent		
BSTR STA	CH 1077206-002					10/14/2010	Absent		
WELL#1	CH 1076263-001					09/07/2010	Absent		
WELL#2	CH 1076263-002					09/07/2010	Absent		
SPNSH GRDNS	CH 1076263-003					09/07/2010	Absent		
WELL#2	CH 1076167-002					09/02/2010	Absent		
WELL#1	CH 1075368-001					08/09/2010	Absent		
WELL#2	CH 1075368-002					08/09/2010	Present		
SKNSN ESTS	CH 1075368-003					08/09/2010	Absent		
WELL#1	CH 1074331-001					07/12/2010	Absent		
RKY BLFS	CH 1074331-002					07/12/2010	Absent		
SPNSH GRDNS	CH 1073525-001					06/14/2010	Absent		
SKNSN ESTS	CH 1073525-002					06/14/2010	Absent		
RKY BLFS	CH 1073525-003					06/14/2010	Absent		
WELL#1	CH 1073346-001					06/07/2010	Absent		
WELL#2	CH 1073346-002					06/07/2010	Present		
BSTR STA	CH 1073346-003					06/07/2010	Present		
WELL#2	CH 1073017-001					05/21/2010	Absent		
WELL#1	CH 1072758-001					05/11/2010	Absent		
SKNSN ESTS	CH 1072758-002					05/11/2010	Absent		
WELL#1	CH 1072118-001					04/13/2010	Absent		
WELL#2	CH 1072118-002					04/13/2010	Absent		
SPNSH GRDNS	CH 1072118-003					04/13/2010	Absent		
WELL#1	CH 1071373-001					03/09/2010	Absent		
WELL#2	CH 1071373-002					03/09/2010	Absent		
SKNSN ESTS	CH 1071373-003					03/09/2010	Absent		
WELL#1	CH 1070865-001					02/08/2010	Absent		
WELL#2	CH 1070865-002					02/08/2010	Absent		
RKY BLFS	CH 1070865-003					02/08/2010	Absent		
WELL#1	CH 1070333-001					01/11/2010	Absent		
WELL#2	CH 1070333-002					01/11/2010	Absent		
BSTR STA	CH 1070333-003					01/11/2010	Absent		

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Copper		ppm		1.3	.17			0.061	5
116 Eagle Nest	CH 1076851-002	ppm				10/01/2010	0.00800		
107 Eagle Nest	CH 1076851-001	ppm				09/30/2010	0.0340		
141 Alm Bluffs	CH 1076851-003	ppm				09/30/2010	0.0120		
99 Alm Bluffs	CH 1076851-004	ppm				09/30/2010	0.0870		
1488 Rim Rock	CH 1076851-005	ppm				09/30/2010	0.00900		
WELL#1	CH 1072825-001	ppm				05/12/2010	0.0200		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		ppm		none	none			7	7 - 7
WELL#1	CH 1072825-001	ppm				05/12/2010	7.00		
Hardness		ppm		none	none			115	115 - 115
WELL#1	CH 1072825-001	ppm				05/12/2010	115		

PRIMARY DRINKING WATER STANDARDS (PDWS)

GRAN MUTUAL WATER CO

Analytical Results By FGL - 2010

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Barium (Ba)		ppm	2	1	2			0.02	0.02 - 0.03
Barium (Ba)									
WELL#2	CH 0979129-001	ppm				12/11/2009	0.0220		
WELL#1	CH 0971368-002	ppm				02/12/2009	0.0278		
Chromium (Total Cr)		ppb	100	50.0				1	0 - 2
WELL#2	CH 0979129-001	ppb				12/11/2009	0.00		
WELL#1	CH 0971368-002	ppb				02/12/2009	2.00		
Nitrate (NO3)		ppm		45	45			1.4	0.8 - 2
WELL#1	CH 1076167-001	ppm				09/02/2010	1.50		
WELL#2	CH 1076167-002	ppm				09/02/2010	0.800		
WELL#1	CH 1072825-001	ppm				05/12/2010	1.80		
Nitrate + Nitrite as N		ppm		10	10			0.4	0.4 - 0.4
WELL#1	CH 1072825-001	ppm				05/12/2010	0.400		
Gross Alpha		pCi/L		15				0.5	0.4 - 0.6
WELL#1	CH 0974987-001	pCi/L				07/07/2009	0.426		
WELL#2	CH 0974987-002	pCi/L				07/07/2009	0.605		
Total Radium 228		pCi/L		5				0.01	0.0 - 0.03
WELL#1	CH 0881526-001	pCi/L				12/31/2008	0.022		
WELL#2	CH 0881526-002	pCi/L				12/31/2008	0.029		
WELL#1	CH 0878366-001	pCi/L				09/16/2008	0.000		
WELL#2	CH 0878366-002	pCi/L				09/16/2008	0.000		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		ppm		500				2	2 - 2
WELL#1	CH 1072825-001	ppm				05/12/2010	2.00		
Specific Conductance		umhos/cm		1600				238	238 - 238
WELL#1	CH 1072825-001	umhos/cm				05/12/2010	238		
TDS		ppm		1000				140	140 - 140
WELL#1	CH 1072825-001	ppm				05/12/2010	140		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Vanadium		ppm		NS				0.007	0.006 - 0.008
WELL#2	CH 0979129-001	ppm				12/11/2009	0.00800		
WELL#1	CH 0971368-002	ppm				02/12/2009	0.00600		

GRAN MUTUAL WATER CO

CCR Login Linkage - 2010

FGL CODE	DATE SAMPLED	LAB ID	METHOD	DESCRIPTION	PROPERTY
107 Eagle Nest	09/30/2010	CH 1076851-001	Metals, Total	107 Eagle Nest	Lead & Copper Monitoring
116 Eagle Nest	10/01/2010	CH 1076851-002	Metals, Total	116 Eagle Nest	Lead & Copper Monitoring
141 Alm Bluffs	09/30/2010	CH 1076851-003	Metals, Total	141 Alm Bluffs	Lead & Copper Monitoring
1488 Rim Rock	09/30/2010	CH 1076851-005	Metals, Total	1488 Rim Rock	Lead & Copper Monitoring
99 Alm Bluffs	09/30/2010	CH 1076851-004	Metals, Total	99 Alm Bluffs	Lead & Copper Monitoring
BSTR STA	01/26/2009	CH 0970786-003	Coliform	Booster Station	Drinking Water Monitoring
	09/08/2009	CH 0976915-003	Coliform	Booster Station	Water Monitoring
	01/11/2010	CH 1070333-003	Coliform	Booster Station	Water Monitoring
	06/07/2010	CH 1073346-003	Coliform	Booster Station	Water Monitoring
	10/14/2010	CH 1077206-002	Coliform	Booster Station	Drinking Water Monitoring
RKY BLFS	01/19/2009	CH 0970620-003	Coliform	Rocky Bluffs	Drinking Water Monitoring
	02/09/2009	CH 0971244-001	Coliform	Rocky Bluffs	Drinking Water Monitoring
	03/10/2009	CH 0971943-003	Coliform	Rocky Bluffs	Water Monitoring
	06/10/2009	CH 0974342-003	Coliform	Rocky Bluffs	Water Monitoring
	10/06/2009	CH 0977609-003	Coliform	Rocky Bluffs	Drinking Water Monitoring
	02/08/2010	CH 1070865-003	Coliform	Rocky Bluffs	Water Monitoring
	06/14/2010	CH 1073525-003	Coliform	Rocky Bluffs	Drinking Water Monitoring
	07/12/2010	CH 1074331-002	Coliform	Rocky Bluffs	Drinking Water Monitoring
	11/09/2010	CH 1077686-002	Coliform	Rocky Bluffs	Water Monitoring
SKNSN ESTS	01/19/2009	CH 0970620-002	Coliform	Skansen Estates	Drinking Water Monitoring
	01/26/2009	CH 0970786-002	Coliform	Skansen Estates	Drinking Water Monitoring
	02/02/2009	CH 0970943-004	Coliform	Skansen Estates	Drinking Water Monitoring
	02/09/2009	CH 0971244-003	Coliform	Skansen Estates	Drinking Water Monitoring
	04/06/2009	CH 0972559-001	Coliform	Skansen Estates	Drinking Water Monitoring
	07/07/2009	CH 0974988-003	Coliform	Skansen Estates	Drinking Water Monitoring
	11/10/2009	CH 0978509-003	Coliform	Skansen Estates	Water Monitoring
	03/09/2010	CH 1071373-003	Coliform	Skansen Estates	Water Monitoring
	05/11/2010	CH 1072758-002	Coliform	Skansen Estates	Drinking Water Monitoring
	06/14/2010	CH 1073525-002	Coliform	Skansen Estates	Drinking Water Monitoring
SPNSH GRDNS	08/09/2010	CH 1075368-003	Coliform	Skansen Estates	Water Monitoring
	01/14/2009	CH 0970477-003	Coliform	Spanish Gardens	Drinking Water Monitoring
	01/19/2009	CH 0970620-001	Coliform	Spanish Gardens	Drinking Water Monitoring
	01/26/2009	CH 0970786-001	Coliform	Spanish Gardens	Drinking Water Monitoring
	02/02/2009	CH 0970943-003	Coliform	Spanish Gardens	Drinking Water Monitoring
	02/09/2009	CH 0971244-002	Coliform	Spanish Gardens	Drinking Water Monitoring
	05/14/2009	CH 0973561-003	Coliform	Spanish Gardens	Drinking Water Monitoring
	08/10/2009	CH 0976080-003	Coliform	Spanish Gardens	Water Monitoring
	12/08/2009	CH 0979057-003	Coliform	Spanish Gardens	Drinking Water Monitoring
	04/13/2010	CH 1072118-003	Coliform	Spanish Gardens	Water Monitoring
	06/14/2010	CH 1073525-001	Coliform	Spanish Gardens	Drinking Water Monitoring
	09/07/2010	CH 1076263-003	Coliform	Spanish Gardens	Water Monitoring
WELL#1	12/07/2010	CH 1078249-002	Coliform	Spanish Gardens	Water Monitoring
	09/16/2008	CH 0878366-001	Metals, Total	Only Well	Drinking Well Monitoring
	09/16/2008	CH 0878366-001	Radio Chemistry	Only Well	Drinking Well Monitoring
	09/16/2008	CH 0878366-001	Wet Chemistry	Only Well	Drinking Well Monitoring
	12/31/2008	CH 0881526-001	Radio Chemistry	Well #1	GRAN MUTUAL WATER CO
	01/14/2009	CH 0970477-001	Coliform	Well #1	Drinking Water Monitoring
	02/02/2009	CH 0970943-001	Coliform	Well #1	Water Monitoring
	02/09/2009	CH 0971244-004	Wet Chemistry	Well #1	GRAN MUTUAL WATER CO
	02/12/2009	CH 0971368-002	Metals, Total	Well #1	GRAN MUTUAL WATER CO
	02/12/2009	CH 0971368-003	Asbestos	Well #1	GRAN MUTUAL WATER CO
	02/12/2009	CH 0971368-003	Wet Chemistry	Well #1	GRAN MUTUAL WATER CO
	03/10/2009	CH 0971943-001	Coliform	Well #1	Water Monitoring
	04/06/2009	CH 0972559-003	Coliform	Well #1	Drinking Water Monitoring
	05/14/2009	CH 0973561-001	Coliform	Well #1	Drinking Water Monitoring
	06/10/2009	CH 0974342-001	Coliform	Well #1	Water Monitoring
	07/07/2009	CH 0974987-001	Radio Chemistry	Well #1	Radiological Monitoring
	07/07/2009	CH 0974988-001	Coliform	Well #1	Water Monitoring
	08/10/2009	CH 0976080-001	Coliform	Well #1	Water Monitoring

GRAN MUTUAL WATER CO

CCR Login Linkage - 2010

FGL CODE	DATE SAMPLED	LAB ID	METHOD	DESCRIPTION	PROPERTY
WELL#1	09/08/2009	CH 0976915-001	Coliform	Well #1	Water Monitoring
	09/16/2009	CH 0977208-001	Wet Chemistry	Well #1	GRAN MUTUAL WATER CO
	10/06/2009	CH 0977609-001	Coliform	Well #1	Water Monitoring
	11/10/2009	CH 0978509-001	Coliform	Well #1	Water Monitoring
	12/08/2009	CH 0979057-001	Coliform	Well #1	Water Monitoring
	01/11/2010	CH 1070333-001	Coliform	Well #1	Water Monitoring
	02/08/2010	CH 1070865-001	Coliform	Well #1	Water Monitoring
	03/09/2010	CH 1071373-001	Coliform	Well #1	Water Monitoring
	04/13/2010	CH 1072118-001	Coliform	Well #1	Water Monitoring
	05/11/2010	CH 1072758-001	Coliform	Well #1	Drinking Water Monitoring
	05/12/2010	CH 1072825-001	General Mineral	Well #1	GRAN MUTUAL WATER CO
	05/12/2010	CH 1072825-001	Metals, Total	Well #1	GRAN MUTUAL WATER CO
	05/12/2010	CH 1072825-001	Wet Chemistry	Well #1	GRAN MUTUAL WATER CO
	06/07/2010	CH 1073346-001	Coliform	Well #1	Water Monitoring
	07/12/2010	CH 1074331-001	Coliform	Well #1	Water Monitoring
	08/09/2010	CH 1075368-001	Coliform	Well #1	Water Monitoring
	09/02/2010	CH 1076167-001	Wet Chemistry	Well #1	Water Monitoring
	09/07/2010	CH 1076263-001	Coliform	Well #1	Water Monitoring
	10/18/2010	CH 1077235-001	Coliform	Well #1	GRAN MUTUAL WATER CO
WELL#2	09/16/2008	CH 0878366-002	EPA 524.2	Well 02	New Well Not in SWDB as of 3/17/08 rrh
	09/16/2008	CH 0878366-002	Metals, Total	Well 02	New Well Not in SWDB as of 3/17/08 rrh
	09/16/2008	CH 0878366-002	Radio Chemistry	Well 02	New Well Not in SWDB as of 3/17/08 rrh
	09/16/2008	CH 0878366-002	Wet Chemistry	Well 02	New Well Not in SWDB as of 3/17/08 rrh
	12/31/2008	CH 0881526-002	Radio Chemistry	Well 02	GRAN MUTUAL WATER CO
	01/14/2009	CH 0970477-002	Coliform	Well 02	Drinking Water Monitoring
	02/02/2009	CH 0970943-002	Coliform	Well 02	New Well Not in SWDB as of 3/17/08 rrh
	02/09/2009	CH 0971244-005	Wet Chemistry	Well 02	New Well Not in SWDB as of 3/17/08 rrh
	02/12/2009	CH 0971368-001	EPA 524.2	Well 02	New Well Not in SWDB as of 3/17/08 rrh
	03/10/2009	CH 0971943-002	Coliform	Well 02	Water Monitoring
	04/06/2009	CH 0972559-002	Coliform	Well 02	Drinking Water Monitoring
	05/14/2009	CH 0973561-002	Coliform	Well 02	Drinking Water Monitoring
	06/10/2009	CH 0974342-002	Coliform	Well 02	Water Monitoring
	07/07/2009	CH 0974987-002	Radio Chemistry	Well 02	Radiological Monitoring
	07/07/2009	CH 0974988-002	Coliform	Well 02	Water Monitoring
	08/10/2009	CH 0976080-002	Coliform	Well 02	Water Monitoring
	08/13/2009	CH 0976226-001	EPA 524.2	Well 02	New Well Not in SWDB as of 3/17/08 rrh
	09/08/2009	CH 0976915-002	Coliform	Well 02	Water Monitoring
	09/16/2009	CH 0977208-002	Wet Chemistry	Well 02	GRAN MUTUAL WATER CO
	10/06/2009	CH 0977609-002	Coliform	Well 02	Water Monitoring
	11/10/2009	CH 0978509-002	Coliform	Well 02	Water Monitoring
	12/08/2009	CH 0979057-002	Coliform	Well 02	Water Monitoring
	12/11/2009	CH 0979129-001	Metals, Total	Well 02	New Well Not in SWDB as of 3/17/08 rrh
	12/11/2009	CH 0979129-001	Wet Chemistry	Well 02	New Well Not in SWDB as of 3/17/08 rrh
	01/11/2010	CH 1070333-002	Coliform	Well 02	Water Monitoring
	02/08/2010	CH 1070865-002	Coliform	Well 02	Water Monitoring
	03/09/2010	CH 1071373-002	Coliform	Well 02	Water Monitoring
	04/13/2010	CH 1072118-002	Coliform	Well 02	Water Monitoring
	05/21/2010	CH 1073017-001	Coliform	Well 02	New Well Not in SWDB as of 3/17/08 rrh
	06/07/2010	CH 1073346-002	Coliform	Well 02	Water Monitoring

GRAN MUTUAL WATER CO

CCR Login Linkage - 2010

FGL CODE	DATE SAMPLED	LAB ID	METHOD	DESCRIPTION	PROPERTY
WELL#2	08/09/2010	CH 1075368-002	Coliform	Well 02	Water Monitoring
	09/02/2010	CH 1076167-002	Coliform	Well 02	Water Monitoring
	09/02/2010	CH 1076167-002	Wet Chemistry	Well 02	Water Monitoring
	09/07/2010	CH 1076263-002	Coliform	Well 02	Water Monitoring
	10/14/2010	CH 1077206-001	Coliform	Well 02	Drinking Water Monitoring
	11/09/2010	CH 1077686-001	Coliform	Well 02	Water Monitoring
	12/07/2010	CH 1078249-001	Coliform	Well 02	Water Monitoring